

## Topic #5 - Advanced Microgrid Control and Protection



Ben Ollis, ORNL  
Max Ferrari, ORNL  
Travis Smith, ORNL

Matt Reno, SNL  
Mike Ropp, SNL  
Lee Rashkin, SNL

Wei Du, PNNL  
Frank Tuffner, PNNL

Ravindra Singh, ANL

Art Barnes, LANL

Yashen Lin, NREL  
Kumaraguru Prabakar, NREL

Vaibhav Donde, LLNL

Ciaran Roberts, LBNL

**3/19/2021**

## DOCUMENT AVAILABILITY

Reports produced after January 1, 1996, are generally available free via US Department of Energy (DOE) SciTech Connect.

**Website** [www.osti.gov](http://www.osti.gov)

Reports produced before January 1, 1996, may be purchased by members of the public from the following source:

National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
**Telephone** 703-605-6000 (1-800-553-6847)  
**TDD** 703-487-4639  
**Fax** 703-605-6900  
**E-mail** [info@ntis.gov](mailto:info@ntis.gov)  
**Website** <http://classic.ntis.gov/>

Reports are available to DOE employees, DOE contractors, Energy Technology Data Exchange representatives, and International Nuclear Information System representatives from the following source:

Office of Scientific and Technical Information  
PO Box 62  
Oak Ridge, TN 37831  
**Telephone** 865-576-8401  
**Fax** 865-576-5728  
**E-mail** [reports@osti.gov](mailto:reports@osti.gov)  
**Website** <http://www.osti.gov/contact.html>

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Division or Program Name

**Topic #5 - Advanced Microgrid Control and Protection**

Author(s)

**Ben Ollis  
Max Ferrari  
Travis Smith  
Matt Reno  
Mike Ropp  
Lee Rashkin  
Wei Du  
Frank Tuffner  
Ravindra Singh  
Art Barnes  
Yashen Lin  
Kumaraguru Prabakar  
Vaibhav Donde  
Ciaran Roberts**

Date Published:  
8/15/2022

Prepared by  
OAK RIDGE NATIONAL LABORATORY  
Oak Ridge, TN 37831-6283  
managed by  
UT-BATTELLE, LLC  
for the  
US DEPARTMENT OF ENERGY  
under contract DE-AC05-00OR22725



# CONTENTS

CONTENTS.....	iii
Executive Summary .....	1
1. Introduction.....	2
2. Vision for the future.....	3
2.1 Controls for a Distributed grid .....	3
2.1.1 Normal Operations.....	3
2.1.2 Grid-Independent Operations.....	3
2.1.3 Blackstart Capabilities .....	4
2.1.4 Multi-microgrid Control .....	4
2.2 Protecting a distributed grid .....	5
2.2.1 Future Protection Methods.....	5
2.2.2 The Role of Device Controls .....	5
2.3 Communications and Cyber Security .....	5
2.3.1 Communications .....	5
2.3.2 Cyber Security .....	6
3. Technology Developments .....	7
3.1 Control .....	7
3.1.1 Hierarchical, distributed, and hybrid control strategies for devices, microgrids, and networked microgrids.....	7
3.1.2 Identification of critical device information for control and modelling, including inverter transient response characteristics and operational capabilities / limits.....	7
3.1.3 Characterizing the dynamic response of power electronic connected loads to system disturbances to ensure no adverse control loop interactions across both generation and load resources .....	7
3.1.4 Dynamic stability region calculation and state estimation for robust off-grid controls, including imbalanced system controls .....	7
3.1.5 Bulk system interactions and grid service provisioning .....	7
3.1.6 Grid-forming inverter control and off-grid behavioral characteristics.....	8
3.1.7 Seamless online transition from grid-forming mode of operation to grid- following mode of operation.....	8
3.1.8 Black-start capabilities of DERs and microgrids – local and bulk .....	8
3.1.9 Network reconfiguration of microgrids and multi-microgrid systems.....	8
3.1.10 Integration of legacy devices .....	8
3.2 Protection .....	9
3.2.1 Inverter fault modelling and estimation techniques .....	9
3.2.2 Improved and standardized Inverter controls for improving protection coordination, including specification of zero-sequence contributions of inverters .....	9
3.2.3 Protection schemes with low fault currents .....	9
3.2.4 Re-coordination of devices in a dynamic environment.....	10
3.2.5 Microgrid grounding .....	10
3.2.6 DC microgrid protection and fault extinguishing devices .....	10
3.3 Communication.....	11
3.3.1 Reliable, high-speed communication is key for many microgrid protection methods including differential, setting-less and double-ended traveling wave .....	11
3.3.2 Cyber security of hardware and communications to secure a large number of endpoints .....	11
3.3.3 Abstraction of behaviors to standardize controller/controlee interactions .....	11
3.3.4 Data aggregation & filtering methods to extract only necessary data.....	11

4.	Use Case / Scenario Examples.....	13
4.1	Device – level .....	13
	Device-level controls play a crucial role in how microgrids are controlled and protected. There is no guarantee that behavior of DERs will be common amongst device types or even amongst vendors. This complicates control philosophies and can lead to unintended and unmodelled instabilities in the microgrid. Furthermore, the parameters which dictate how the device responds to grid events are often not reported, and assumptions must be made in any transient simulation, leading to inaccuracies.....	13
4.2	Single Microgrids.....	13
4.3	Multi-microgrids .....	13
5.	Enabling Technologies .....	15
6.	Summary of Research Targets & Goals for next 10 years.....	16
7.	Why Should DOE be Funding These Goals and Vision.....	18
8.	References.....	19
9.	IAB Members .....	21
	Appendix A.....	2

## EXECUTIVE SUMMARY

The growing number and variety of microgrids being deployed today introduces challenges and complexities in control and protection design for microgrids. No longer are microgrids only used in remote applications with a dependence on traditional generation; many existing microgrids provide grid services and support, operate with a mix of renewable generation, and can seamlessly go from grid-connected to islanded for enhanced reliability. Additionally, increasing attention is being given to multi-microgrid systems and interactions between their controls and utility control systems. If microgrids are to become ubiquitous, it will require advanced methods of control and protection ranging from low-level inverter controls that can respond to faults to high-level multi-microgrid coordination to operate and protect the system.

Microgrids are inherently dynamic systems due to their ability to operate grid-connected or islanded, with different system requirements in each operational mode. Our vision for the future of microgrids includes the ability to adapt and operate efficiently to perpetually changing grid conditions through controls while simultaneously protecting the system and its customers. Achieving this vision will require developing innovative technologies, control algorithms, sensors, and protection schemes. These developments will advance microgrid protection systems and maximize system resilience, reliability, efficiency and minimize grid modernization cost.

The motivation for this report is to identify the challenges and technological advancements needed by microgrids in the coming 5-10 years, and how microgrids can achieve: (1) higher resiliency for electric delivery systems, (2) lower carbon footprint, and (3) more cost-effective electric grid operations, achieved through reducing implementation and operation costs, all while targeting that at least 40% of microgrid benefits go to disadvantaged communities. These goals will support the microgrid program's vision statement:

*By 2035, microgrids are envisioned to be essential building blocks of the future electricity delivery system to support resilience, decarbonization, and affordability. Microgrids will be increasingly important for integration and aggregation of high penetration distributed energy resources. Microgrids will accelerate the transformation toward a more distributed and flexible architecture in a socially equitable and secure manner.*

This report identifies research and development (R&D) areas targeting advancement of microgrid protection and control in an increasingly complex future of microgrids. To identify these areas, we considered microgrids with multiple points of interconnections, combinations of hybrid AC/DC microgrids, networked microgrids, microgrids within microgrids, and microgrids inside secondary networks.

## 1. Introduction

For years, microgrids have been considered for providing resilience to critical infrastructure, remote areas, and during emergencies. This is partially due to a microgrid's ability to flexibly serve loads using a variety of generation sources, and partially to provide nearly uninterruptible power for many applications. As microgrid technology has matured, it has become clear that microgrids can play a part in normal distribution system operations instead of as only a sophisticated backup system. This will require inspection of device level controls, individual microgrids, and systems of multiple microgrids. This paper will lay out methods for controlling and protecting microgrid systems to **enable a low-carbon, resilient, cost effective grid of the future**.

Microgrid controls and protection will be critical in a future where a significant increase in DER penetration is expected (30-50% of total generation capacity in the next decade). Specifically, control and protection will be leveraged to achieve:

1. A future electric deliver system (EDS) where microgrids act as a core solution to **increase the resilience and reliability** of critical infrastructure and alleviate social burdens associated with grid stress and outages.
2. A **decarbonized** future where microgrids utilize advanced controls and protection methods to better integrate renewable energy sources into the EDS, with 50% of all newly installed DER within microgrids being renewable by 2030.
3. A **reduction in microgrid capital costs** by 15%, as well as a **reduction in project development, construction, and commissioning** by 20% by 2031.

Achieving this future will require research in three categories: (1) technology development, (2) analysis and tools for planning, and (3) institutional frameworks. This paper will focus mostly on research in category 1, technology development for microgrids, specifically addressing microgrid control and protection technologies.

The paper will present the many technical areas of microgrids which play a part in how they are controlled and protected, from device-level to system-of-systems level. We expand on the current state of the art by first laying out our vision for how microgrids should be controlled and protected in the next 10 years. This vision will be used to identify the gaps between today's technology and where research can accelerate progress in the areas of microgrid control, protection, and communications. Ongoing projects in these areas will be identified and will feed into a multi-year research plan to accomplish the vision statement. Lastly, we provide a brief justification on why DOE should drive research in this area.



## **2. VISION FOR THE FUTURE**

Future power systems are expected to see an increase in distributed energy resources, with potential for up to 30%-50% of all generation to be located on the distribution system. This poses a challenge for utility operators in both the need to coordinate such distributed energy resources as microgrids or to mitigate the changes in power flow under grid-connected operation. Additionally, this continues the trend of distribution networks transitioning from passive networks to more dynamic systems, with control-loop interactions, both within and across distribution systems.

Microgrids are expected to increase both in the number of installations, but also the size and spatial extent of microgrid installations. Additionally, collections of networked microgrids both customer- and utility-owned are expected to be able to connect on distribution networks to increase efficiency and reliability by taking advantage of additional load diversity, larger numbers of generators and multiple paths between generation and loads. New sensing technologies, protection schemes and inverter controls enable the operation of such networked microgrids in terms of providing black start capability and protection coordination.

### **2.1 CONTROLS FOR A DISTRIBUTED GRID**

#### **2.1.1 Normal Operations**

Grid-tied operation of microgrids is considered “normal operations”. Most non-remote microgrids will operate grid-tied by default and will be able to influence the operations of the local grid and customers. Microgrids today are often subject to interconnection agreements with the local utility (unless utility-owned), and often those contracts will specify the microgrids’ allowable operating ranges and expected behavior, including export restrictions, voltage support, and connect/disconnect criteria. This contract structure works for pre-planned microgrids with known interconnection points to the main grid which can be monitored easily. However, in a future where DERs could be even more distributed, multi-owner, and uncertain boundaries, the interconnection agreements can quickly become burdensome to utilities, and can even limit the efficacy of the DERs to support the bulk grid.

Additionally, the intersection between multiple domains of energy consumption will become more apparent and need to be accounted for. Controllers will need to be aware of building-level controls, EV charging, and integrate with weather stations, district heating, and fueling infrastructure.

In a future grid, we would expect to see controllers dynamically respond to grid conditions, self-optimizing and reconfiguring to best serve its customers without putting undue strain on the electric system. Multi-objective optimizations will allow microgrids to balance operating costs, resiliency, and uncertainty. A myriad of different control schemes can be utilized to achieve these goals. Future DERs and microgrid controllers should be flexible enough and have enough available information to enable many of these differing control methods by standardizing what data is provided and how, which can significantly reduce commissioning times for microgrids.

#### **2.1.2 Grid-Independent Operations**

One of the key characteristics of microgrids is that they can operate in an islanded mode, disconnected from bulk power systems. After a transmission outage caused by extreme weather or natural disasters, using local distributed energy resources (DERs) to operate a distribution feeder, or portions of it as microgrids can minimize the impacts of outages on customers. In addition, the grid-independent operation capability of

microgrids can also benefit remote areas such as rural villages that are far from the bulk power grids; this feature significantly improves the reliability and resiliency of power grids. However, the grid-independent operation of microgrids also brings new technical challenges, such as the low system inertia, a lack of fast regulation devices, and the uncertainties of inverter-based renewables. These challenges should be addressed at both the primary and secondary control layers. At the primary control layer, new control strategies for inverter-based DERs such as grid-forming with droop control should be studied to ensure system stability, and coordinated protection. At the secondary control layer, the microgrid controller should be designed to operate and dispatch the DERs by overcoming the uncertainties/intermittencies caused by high penetration inverter-based renewables. Meanwhile, the power system must operate without interruption should loads trip, transmission interconnections open, generation trips, and/or communication failures of any kind occur. In addition, a smooth transition between the grid-connected mode and islanded mode should be guaranteed with or without the microgrid controllers in service. Degraded frequency and voltage performance should be allowed in these multiple contingency outage scenarios, but the flow of energy to society must not stop.

Finally, research is needed with regards to emergency response to unanticipated grid loss. Within the context of microgrids, effective ways to maintain power to specific subsets of the grid without even momentary interruption during grid loss will massively benefit industrial processes, medical facilities, and critical service providers. Fail-over to diesel generators does not prevent the momentary outages that could result in millions of dollars in lost industrial processes, expensive medical equipment restarts (e.g., MRI), and emergency service interruption.

### **2.1.3 Blackstart Capabilities**

In an ideal world, a microgrid is always able to isolate and operate in grid-independent mode for as long as necessary before closing back into the main grid. In reality, unforeseen outages, internal faults, insufficient generation, controller instabilities, and/or a number of other scenarios can cause microgrid failure. In the future, certain microgrids should be designed in such a way to enable blackstart for critical loads. While blackstart generators have been used in practice for many years, more research should be given to renewable and inverter-based DERs as blackstart devices. Because inverter base resources have strict current limiting behavior, they exhibit severe cold load pickup and magnetic inrush limitations, for example the best battery inverter systems today can only pickup less than 20% of their nameplate, whereas generators can be counted on to cold load pickup over 50% of their nameplate

One solution is to specify inverters to source the inrush currents of transformers and large motor loads, while recovering the voltage and providing a strong frequency reference for other DERs and loads. Another solution used today but which needs more research is to incrementally add transformers and loads back thereby not overloading inverters.

Going beyond the traditional boundaries of a microgrid, more work must be done in exploring how a microgrid can support the blackstart of feeder sections, entire feeders, substations, and even support the local transmission system. This would require an increase in the level of device coordination on the distribution system as well as additional planning models for multi-microgrid systems and significant retraining of the utility workforce to ensure safe operation and restoration.

### **2.1.4 Multi-microgrid Control**

The future distribution systems are expected to have a high penetration of microgrids deployed by different vendors and owned by different owners. Interconnecting geographically close microgrids as networked microgrids can further enhance the reliability and resilience of power systems. Currently there are only a

few deployments of networked microgrid in the real world. Therefore, a significant amount of research efforts is needed to develop appropriate control and coordination strategies to support the operation of the multi-vendor and multi-owner networked microgrids. Both centralized and decentralized approaches should be investigated to understand their applicability to the networked microgrids.

## **2.2 PROTECTING A DISTRIBUTED GRID**

### **2.2.1 Future Protection Methods**

Although commercial microgrid deployments are proliferating, the spatial extent of such microgrids is limited by the limitations of the state-of-the-art in microgrid protection. An unfortunate fact is that microgrid protection largely focuses on shutting down inverter generation to protect the power electronics, rather than minimizing the outage area. New protection methods are needed that can operate with inverter-interfaced microgrids while providing protection coordination. This will enable the reliable operation of large and networked microgrids even during disaster events, where causes such as severe weather can cause faults on an operating microgrid.

### **2.2.2 The Role of Device Controls**

The varying behavior of microgrid inverters under short-circuit conditions is a gap in existing microgrid standards. This creates difficulties for both the protection engineer who wishes to simulate a microgrid under short-circuit conditions to design and test a protection system, and inherent difficulties for the protective relaying itself in some conditions.

## **2.3 COMMUNICATIONS AND CYBER SECURITY**

### **2.3.1 Communications**

Novel control and protection of distributed resources are often reliant on some form of communication. Devices are expected to report measurements and be configurable for controllers. Controllers are expected to provide control points and data to SCADA systems. Feeder management systems may be expected to provide weather and pricing forecasts to microgrid controllers to influence control actions.

For future operations, we should consider that microgrid controllers may need to interact with large numbers of DERs spread across a wide area including multi-owner and multi-vendor assets. Microgrid controllers will also be expected to interact with other microgrid and feeder controllers, as well as SCADA and DERMS systems. To enable this highly complex assembly of DERs and utility systems, research is required on what will be required for DERs to report to microgrid controllers in terms of measurements, behavioral characteristics, and capabilities.

Thus, an opportunity exists to standardize behavior of Intelligent Electronic Devices (IEDs) when given standardized commands such as activate and deactivate, new setpoints, and measurement requests. This is a marked difference from adoption of a new data schema in that it would not require adoption of any particular structure, but would instead be a standardized behavioral response when the IED is presented with the command. Research in this area would lead to heightened interoperability between IEDs, microgrid controllers, historians, and SCADA systems in general.

An additional emerging research area is one focused on the effectiveness, security, and feasibility of inter-device communication. Traditional communication structure utilizes a spoke-and-wheel approach where direct communication between devices is generally denied. While this decreases the number of

communication pathways an attacker could attempt to compromise, it limits the speed at which decisions can be made between multiple devices at the edge. These decisions could be real-time PV smoothing algorithms, co-sharing of V/f regulation for redundancy and stability, and rapid response to operational changes in geographically near devices. Moreover, by enforcing communication through a centralized area like a command room at a distribution center, there is generally a single point of failure for the communications exiting the substation or generation facility, thereby preventing the kind of inter-device communication that would be needed for effective autonomous operation until communications were re-established.

The role of non-communication-based microgrids is another area of continued attention. While communication capabilities continue to become more sophisticated, there is no guarantee of perfect reliability. Alternative methods of controlling microgrids have been demonstrated in the past, based mostly on droop control, but further attention should be given to this area to determine if other methods are capable of supporting microgrids when communication is lost.

### **2.3.2 Cyber Security**

Microgrids are effective in ensuring energy availability to critical infrastructure nodes of a network during prolonged outages due to successful cyberattacks, thereby enhancing the overall resilience. With increasing rates of data acquisition and no vendor agnostic cybersecurity posture, distribution systems pose unique challenges that transmission systems do not. Coupled with a broadening attack surface, these make microgrids lucrative targets for coordinated attacks. A microgrid control system (MCS) coordinates among individual resources and abstracts the microgrid as a single entity when communicating with the main grid. A poor cybersecurity posture could, therefore, render MCS a single point of failure for the entire microgrid.

### 3. TECHNOLOGY DEVELOPMENTS

In a future grid where microgrids become a ubiquitous solution to integrating DERs and maintaining system reliability, many new technologies and methods will be required. These include:

#### 3.1 CONTROL

##### 3.1.1 Hierarchical, distributed, and hybrid control strategies for devices, microgrids, and networked microgrids

Multiple valid control strategies for microgrids exist, and they each warrant research into their strengths and weaknesses. There is no prescriptive method for microgrid control, but instead should aim for an environment which supports multiple methods of control to meet each microgrid's mission.

One such method of creating adaptable controllers is to pursue modularity, such as containerized applications built on top of a framework. This can allow for rapid changes in optimization, data storage, communications, and others without having to change the underlying framework, similar to apps running on an operating system.

##### 3.1.2 Identification of critical device information for control and modelling, including inverter transient response characteristics and operational capabilities / limits

Identification and format of critical information will be needed for controllers to perform their core function. Often, microgrid controls operate on assumptions of device behavioral characteristics, but this is far from an optimal control method. If devices can report their unique operational data and characteristics, that information can be built into the controllers and used to create a more stable microgrid.

##### 3.1.3 Characterizing the dynamic response of power electronic connected loads to system disturbances to ensure no adverse control loop interactions across both generation and load resources

Power electronic interactions on the bulk grid are complex and difficult to model. However, work can be done on methods for characterizing dynamic behavior of sources and loads in a microgrid to build a stronger transient model.

##### 3.1.4 Dynamic stability region calculation and state estimation for robust off-grid controls, including imbalanced system controls

It is critical to maintain the stability of the power system. Unlike the bulk power system, many energy sources in microgrids are connected to the system via power electronic devices. These resources are often distributed and have a wide range of size and control topology, which introduce many challenges to analyze and maintain microgrid stability. Small-signal stability is a necessary requirement and other types of stability, such as transient stability, are also important (Schneider, et al. 2020).

##### 3.1.5 Bulk system interactions and grid service provisioning

While grid services provided by microgrids has been fairly well studied for individual microgrids, there is much work needed in determining how large numbers of microgrids can co-dispatch to provide grid

services. For instance, a large number of microgrids could potentially provide blackstart and frequency regulation services to the main grid, which would be difficult for a single microgrid to accomplish.

### **3.1.6 Grid-forming inverter control and off-grid behavioral characteristics**

Grid-forming inverter control will play an important role in the reliable and resilient microgrid operation. Different from the tradition grid-following inverter control, grid-forming inverters can regulate their terminal voltage and frequency without an external voltage source, which enables inverter-based DERs in the microgrids to help maintain the system voltage and frequency. Although we have seen early deployment of grid-forming inverter in small systems, there are still many open research questions need to be addressed for wide adoption. The challenges include frequency control, voltage control, system protection, fault ride-through and system recovery, and modeling and simulation approaches (Lin, et al. 2020).

### **3.1.7 Seamless online transition from grid-forming mode of operation to grid-following mode of operation**

Many existing grid-forming devices require a shutdown to transition from grid-forming mode to grid-following mode. There are benefits to having seamless transitions of devices, but it is often difficult to achieve in practice. Research is needed on quantifying the benefits and demonstrating the ability for devices to behave in this manner.

### **3.1.8 Black-start capabilities of DERs and microgrids – local and bulk**

Traditionally black-start capability is almost exclusively provided by synchronous generators. However, in microgrids with significant inverter-based resources, it is beneficial to have DERs which could provide black-start support, or use intelligence in the grid to incrementally add loads back during a blackstart. Early work has demonstrated the potential of black-starting with inverter based resources (IBRs), however, many challenges remain, including how to address the stochastic natural of the DERs, how to address the limited short-circuit current from IBRs, and how to develop models and simulations to evaluate the performance of IBR black-start. .

### **3.1.9 Network reconfiguration of microgrids and multi-microgrid systems**

Reconfiguration of distribution systems is a popular academic area of study, however many projects make assumptions about controls, communications, and modelling that are critical to building a functional multi-microgrid system in the field.

### **3.1.10 Integration of legacy devices**

It is unrealistic to assume that all devices on the grid will be replaced in the next 10-20 years. Therefore, new controllers will need the capability to interface with legacy devices and integrate them into a system they were likely not designed for. This is far from trivial, and may require retrofits and additional equipment.

## **3.2 PROTECTION**

### **3.2.1 Inverter fault modelling and estimation techniques**

An ongoing issue in protection of microgrids is how to model them under short-circuit conditions. While there is ongoing research that shows promise for the ability to protect inverter-interfaced microgrids, it is necessary to be able to validate such methods on microgrids of practical size, particularly when considering networked microgrid operation. While it is possible to accomplish this with transient simulation software, models are typically limited to around  $10^4$  electrical nodes, while practical distribution systems can exceed  $10^5$  nodes. Additionally, the number of parameters required for modeling generators and inverters can be prohibitive. An alternate approach is to model the short-circuit behavior in the phasor domain after the initial dc offset of the short-circuit current has died out. This presents a challenge on account of both the nonlinear behavior of inverters and the varying behavior of inverters under short-circuit conditions. For example, grid-following inverters typical of residential photovoltaic systems and grid-forming inverters that are typical of microgrids will respond to faults differently. Additionally, even within these two broad categories there is variation on account of the type of inverter control used (a rotating reference frame or stationary reference frame, incorporating multiple control loops to regulate harmonics, how power sharing is implemented) and how fault current limiting is implemented (whether a simple threshold or hysteresis is used, how the current reference for current-limiting operation is produced). Another complication is how to address current limiting for faults with significant zero-sequence quantities, where a typical three-leg inverter topology will not provide zero-sequence current. There is ongoing work to produce both transient and phasor-based inverter short-circuit models and to validate them against experimental results.

### **3.2.2 Improved and standardized Inverter controls for improving protection coordination, including specification of zero-sequence contributions of inverters**

The previous section on inverter fault modeling highlighted the difficulty of modeling inverters on account of the current lack of standardization. To facilitate design of microgrid protection systems, it is highly recommended to extend existing standards on microgrid protection to include standard behavior for inverters under fault currents. In addition to adding complexity to the modeler or protection designer who is simulating a IBR under fault conditions, some current-limiting methods can cause difficulty for protection. As an example, a simple current threshold will result in voltage and current clipping, causing significant harmonics which will interfere with calculations that are based on phasor quantities.

### **3.2.3 Protection schemes with low fault currents**

Existing protection schemes have documented limitations in microgrids, particularly inverter-interfaced microgrids on account of the lack of fault current. This is the case for standard time-overcurrent protection which will at best have prohibitively long operating times. It is necessary to investigate non-traditional protection methods for distribution, both methods that have been adapted from transmission systems (that normally operate in meshed configuration) and novel protection methods, with a theme being that most methods are some variation of differential protection. It is important to study the applicability of transmission protection methods to microgrids. For example, there is currently a lack of consensus in terms of the usefulness of admittance relaying, where there is evidence suggesting that the line admittances on practical microgrids are too low to reliably discriminate between in- and out-of-zone faults [3, 4, 5]. Novel methods include the family of setting-less/dynamic state estimation protection methods, which overcome issues of current mismatch at the terminals of a protected zone by incorporating a detailed model of the physics of the protected device [6, 7, 8, 9]. An alternate approach that exploits new relaying hardware with high sample rates is traveling-wave protection which makes use of the property that distribution lines can

be modeled as distributed-parameter lines at high frequencies [10, 5]. This allows traveling-wave protection to locate faults based on the timing on current pulses given either knowledge of the line propagation constant or the ability to take multiple measurements on either side of a fault. A last approach takes an integrated view of fault location on a microgrid by deploying micro-PMUs such that the microgrid is observable [5].

### **3.2.4 Re-coordination of devices in a dynamic environment**

A second issue with protection of microgrids is that aside from the low fault currents in inverter-interfaced microgrids, there are also issues on account of varying levels of fault current caused by changing generation dispatch, and switching configurations, which can include the transition between grid-connected and islanded modes [5]. This exposes a second limitation of conventional protection outside of its requirement for fault current as an operating quantity. Typical protective relaying systems for both distribution and transmission are inflexible or used in inflexible manners and are designed to use pre-set protection zones. This can result in misoperation or lack of operation under different microgrid operating configurations. When assessing protection technologies, this needs to be considered [5]. While time-overcurrent protection is certainly affected by microgrid reconfiguration, newer technologies such as setting-less protection and even older ones such as differential protection are immune to change in fault current magnitude and direction.

### **3.2.5 Microgrid grounding**

Grounding of microgrids is one of the most challenging topics for microgrid protection. In grid-connected mode, the system grounding is generally provided by the substation transformer. If the microgrid or DER in the microgrid are grounded during grid-connected operation, it can result in bi-directional ground current flows, desensitization of ground current protection settings, and sympathetic tripping. Once the microgrid is islanded from the rest of the system, the connection to the substation transformer is lost. Without grounding in the microgrid, it is very challenging to detect single-line-to-ground faults (especially for systems that are already fault current limited), there are additional safety risks, and faults can cause extreme temporary overvoltages. For the reason, it is common that the microgrid grounding will be switching in and out during mode transitions, either using a grounding bank or grounding switch on a wye-delta-wye transformer. Controlling this grounding switch, transition timing, handling transformer inrush, and other additional aspects make this a challenging problem. It is also important to size the microgrid grounding appropriately, which can be challenging for inverter-based system where traditional coefficient-of-grounding rules do not apply.

### **3.2.6 DC microgrid protection and fault extinguishing devices**

While this has been an area of long term interest, many practical issues presented as barriers to progress. With recent progress on standardizing DC metering, it is anticipated renewed interest and effort will be placed on protection and fault extinguishing.

Recently, DC microgrids are gaining more popularity as both more generation is DC with power-electronic converters and more energy consumption of lighting and computers shift towards DC. Because DC microgrid are converter-based systems, the entire system has very fast dynamics and can potentially be very sensitive to disturbances and faults. For this reason, fast fault detection schemes need to be developed to



minimize the fault clearing time. Analysis of DC microgrid protection schemes is challenging because 1) as discussed in previous sections each converter controls and operation is unique, and 2) there are limited software available for simulating DC systems. Without appropriate standards and guidelines it is difficult to address the DC microgrid system restoration strategies. There should be more research on this topic to develop proper guidelines for the closing sequence of primary and backup protection devices based on the fault characteristics and system components.

### **3.3 COMMUNICATION**

#### **3.3.1 Reliable, high-speed communication is key for many microgrid protection methods including differential, setting-less and double-ended traveling wave**

Demonstrations of communications-driven protection schemes for microgrids are needed to demonstrate their ability to respond to constantly-shifting microgrid conditions.

#### **3.3.2 Cyber security of hardware and communications to secure a large number of endpoints**

Confidentiality, integrity, and availability are critical to information systems. Continuous energy delivery, on the other hand, is strongly tied to availability and integrity, which gain precedence over confidentiality. However, these two attributes need additional qualifiers to comprehensively represent the security requirements for a microgrid. These qualifiers can be adopted from the Parkerian Hexad into the control systems domain and include possession (continued access control over protected data), utility (usefulness of data in its protected form), and nonrepudiation (ensuring accountability and authorship of data provable via traceable means).

Defense-in-depth and layered defense technologies have been effective models in protecting systems with interdependent subsystems. However, they are limited in their flexibility to adapt to emerging paradigms of decentralized controls and edge or fog computing. Further, well-sponsored coordinated attacks, which have increasingly begun targeting the smart grid, can penetrate every layer of defense to compromise the system. Hence, it is imperative to augment such traditional security models with solutions that are dynamic, data-driven, distributed, and lightweight. Below, the emerging directions of research into microgrid cybersecurity are summarized.

#### **3.3.3 Abstraction of behaviors to standardize controller/controlee interactions**

Often microgrid controllers are designed as one-off systems based on the specific behaviors of the devices within the microgrid. However, if standardized command and control signals are developed, that greatly simplifies the controller's internal state machines and messaging structure, leading to shorter commissioning times and greater interoperability.

#### **3.3.4 Data aggregation & filtering methods to extract only necessary data**

Utilities today are running into big data problems, and most of that data is never utilized. This problem will only get worse as more endpoints on the system return information back to centralized utility systems like SCADA. A method of mitigating the vast amounts of generated data will be through aggregation and

abstraction of certain data fields at the microgrid controller level. While the controller may have access to all information within its domain, only a portion of that data needs to flow upward to the feeder or the utility level.

## **4. USE CASE / SCENARIO EXAMPLES**

For this section, we will bring forth some examples of areas where microgrid control and protection will need to expand to meet the vision laid out in this document.

### **4.1 DEVICE – LEVEL**

Device-level controls play a crucial role in how microgrids are controlled and protected. There is no guarantee that behavior of DERs will be common amongst device types or even amongst vendors. This complicates control philosophies and can lead to unintended and unmodelled instabilities in the microgrid. Furthermore, the parameters which dictate how the device responds to grid events are often not reported, and assumptions must be made in any transient simulation, leading to inaccuracies.

Ideally, DERs reporting to a microgrid controller would provide measurement, status, and behavioral data in a standard format that any microgrid controller could quickly model and implement into an optimization routine. This data should also be able to describe the fault characteristics of the device for inclusion in the protection system design, which will likely be partially controlled by the microgrid controller. While this will require significant changes from vendors, it will ultimately lead to more observable and controllable distribution system.

### **4.2 SINGLE MICROGRIDS**

In the case of single microgrids, there are a multitude of different control paradigms which can be utilized to coordinate and dispatch the DERs and components under its jurisdiction. The goal of this paper is not to be prescriptive in which control methods are preferred, but instead to describe architecture for microgrids which can allow for a multiple control schemes to be achievable.

For the purposes of this exercise, we are considering that a microgrid consists of at least one DER, one load, and at least one controller of some sort. The controllers can be centralized or distributed, and local or remote. The controller(s) will be expected to report information to existing utility systems, such as SCADA, and to coordinate the behavior of some subset of assets within the microgrid, including but not limited to: generation, load, protection, and voltage regulation.

A simple method of integration of a microgrid controller into utility operations would be through abstraction. High-level use cases are presented to the operator (ex., voltage regulation, power factor control, island mode), but most actual control is handled by the remote controller and not the power system operator. This keeps an operator from needing to individually seek out DERs to change setpoints, and instead automates the control and dispatch of the assets. Similarly, protection setting groups can change based on dynamic fault current availability calculations to ensure the grid stays in a “protectable” range. This is a significant shift from how power systems are operated today, but could provide substantial benefits to customers and utilities.

### **4.3 MULTI-MICROGRIDS**

Like the single microgrid case, control for multiple microgrids can take on many forms, including transactive control, game theoretic control, device inheritance, and fully distributed control to name a few. Again, our goal is not to be prescriptive with how multi-microgrid systems are controlled, but instead to describe methods of building out microgrids to enable these types of interactions.

Systems consisting of multiple microgrids are even more complex than previously presented cases, and very few of these systems exist today, so they are not well understood. Commercial controllers today have limited interaction capability with controllers of other vendors, and interactions beyond the boundary of the microgrid are typically not considered. Coordinating controllers through a SCADA or EMS system are likely the short-term solution to this problem but may not be the most practical in a system containing hundreds of microgrids.

A similar architecture to the single microgrid case can be adopted for multiple microgrids. Controllers can establish a secure channel with other controllers to interact, share information, and co-optimize to come to a more global optimal solution than if controllers operated independently. Also, in islanded mode, microgrid systems could share assets to create a larger island, serving more customers and potentially operating more efficiently and reliably. This functionality could be especially useful in areas of natural disaster, where multiple pockets of resilience created by microgrids could be combined and co-optimized to serve a greater number of civilians and rescue/recovery workers.

There is a small pilot, the California Energy Commission-funded Oakland EcoBlock<sup>1</sup> project, underway in the San Francisco Bay area where the utility plans to enable sectionalizing a short, single-phase 2.7-kV (line-to-neutral) lateral distribution feeder and operating it as an island during grid outages. Under blue-sky conditions, the 150-kW battery resource can be dispatched as desired to support transmission or distribution level objectives, depending on tariff design and real-time needs. The goal of this project is to prototype block-level microgrids that are scalable and both offer grid-services in grid-connected mode and serving all microgrid critical loads for several days in case of an outage.

---

<sup>1</sup> <https://ecoblock.berkeley.edu/>

## 5. ENABLING TECHNOLOGIES

A future which enables more flexible and effective microgrid controls and protection will be an enabling technology for all other topic areas of this report. Without effective methods of collecting information, understanding device dynamics, abstracting behavioral characteristics, and protecting infrastructure, it will be very difficult to achieve a future in which microgrids can achieve our targets for low-carbon generation, system resiliency, and affordability. Creating a control and protection framework which is replicable will enable microgrids building blocks (Topic 3) and microgrids as a building block for the grid (Topic 4) and will leverage work done with co-simulation of microgrids (Topic 2), planning and design tools (Topic 6), and regulatory and business models for microgrids (Topic 7).

Work has already begun on many of the enabling technologies for the proposed future distribution grid, including:

- Standardized data models for DERs
- Device abstraction layers for simplified commissioning
- Microgrid control methods and multi-microgrid interactions
- Protection schemes that do not depend on fault current and are robust to changing network configurations
- Dynamic protection schemes based on changing electrical layout
  - Setting-less/dynamic state estimation based protection
- Formulations and software tool implementations for
  - Short-circuit contribution of inverters (grid-forming and grid-following)
  - Protection and stability constrained operation of microgrids
  - Protection system design of microgrids that accounts for non-radial operation
- Inverter control loop classification (grid-forming and grid-following)
- Imbalanced system controls
- Protection for DC microgrids
- Protection standards for microgrids
  - Standardized behavior of microgrid inverters under fault, particularly current limiting
- Secure DER hardware and communications

The CERTS microgrid has explored some of these control and protection challenges on a small testbed and lesson learned from these experiments can help drive future research. All network and controller data related to the microgrid are publicly available<sup>2</sup> as well as all waveform test data<sup>3</sup>. This data spans all three phases of the project, when the microgrid was operating as an all grid-forming inverter-based microgrid, as well as when grid-forming inverters were operating in parallel with synchronous machines. Furthermore, this data also captures an alternative approach to electrical protection within the microgrid that does not depend on being triggered by abnormally large electrical currents.

---

<sup>2</sup> <https://certs.lbl.gov/initiatives/certs-microgrid-test-bed>

<sup>3</sup> URL forthcoming

## **6. SUMMARY OF RESEARCH TARGETS & GOALS FOR NEXT 10 YEARS**

Here, the authors outline research goals needed to achieve the future vision laid out previously.

### **1-3 years:**

- Building and testing of testbeds and field validations for networked microgrids, as started by active DOE projects
- Participation in ongoing standards efforts for microgrid protection schemes and DER communication schemas. This includes standards for microgrid protection, such as 2030.12, standards for microgrid and DER grounding, and standards for DC microgrid protection.
- Characterization of inverter controls in grid-forming and grid-following modes, including transitions between modes and under faults
- Analyze how inverter grid support functions (ride-throughs, 2800 functions, etc.) impact the microgrid protection system
- Modelling and simulation of resiliency of multi-microgrid systems primarily based on renewable generation
- Developing analytical methods to determine effective grounding resistance and reactance for inverter-based systems
- Development of a hardware roadmap to identify critical operational capabilities needed to effectively utilize a DER in a microgrid
- Development of a regulatory roadmap for how multi-owner microgrids can be controlled
- Development of fast fault detection schemes for DC microgrids, including arc fault detection, and fault location in DC systems
- Improved DC circuit breaker technologies, such as solid-state circuit breaker development, and testing of DC fault extinguishing devices
- Develop framework for coordination between the microgrid protection and ADMS
- Research for improved cyber security of protection communication and communication between the protective devices and the microgrid controller or DMS.

### **3-5 years:**

- Identify a method of enabling discovery and assimilation of new DERs into existing microgrid controllers
- Include IoT load controls, EV charging, customer storage into microgrid controller controls and constraints.
- Perform a future-looking simulation for low carbon microgrids including protection systems and high electric vehicle penetration
- Improvements for microgrid grounding, such as novel microgrid protection schemes for detection of ground faults with a good grounding source, new power electronics based grounding sources, and improved performance of inverter controls under unbalanced non-symmetrical grid conditions.
- Demonstrate novel protection and control methods through large-scale co-simulation of low carbon microgrids

- Algorithms for optimal protection design in microgrids based on generation locations, PCC, fault current, and critical loads. This includes design techniques to determine appropriate protection settings for real-time applications, planning, or adaptive protection. The design and setting algorithms could include machine learning algorithms using historical fault and outage data.
- Development of new protection schemes for meshed microgrid architectures and microgrids in secondary networks. The protection scheme must be able to handle reverse power to distinguish between generation from the microgrid and reverse current from a fault being supplied through the network. This includes hardware-in-the-loop testing of microgrid protection schemes in secondary networks.
- Autonomous self-healing protection schemes for a fractal grid
- Advancement of commercial short circuit current software to include grid-forming inverter models and the ability to analyze microgrid protection

#### **5-10 years:**

- Lab and field demonstrations of networked microgrid controls and protection
- Effective HMI and processing of data to support power system operators
- Research and designs of new protection techniques, schemes, and equipment for DC, networked, and hybrid microgrids
- Coordinated operation of inverters with protective relays
- Generic protection schemes and devices for microgrid deployments
- Development and demonstration of communication-based microgrid protection schemes (such as settingless state estimation protection) integrating additional sensing technologies (fault indicators, PMU, etc.)
- Automated compliance testing for protective devices using digital twins and HIL

## **7. WHY SHOULD DOE BE FUNDING THESE GOALS AND VISION**

Today's microgrid controllers, DERs, and protective devices tend to be purpose-built, and also do very well at achieving that designed purpose. As a side effect of this, much time is spent perfecting a given technology as opposed to innovating. Utilities also tend to be risk-averse; often utilizing products they know and trust over equipment with new capabilities. Most utilities have a "show me" policy regarding hardware, as any technology that fails will likely have a detrimental effect on its customers' costs and quality of service. This results in low motivation for vendors to constantly change their product line beyond minor improvements.

In this environment, the DOE can play a crucial role in spurring research to push beyond the industry standard. Working with vendors and utilities, the labs can demonstrate technologies in simulation, hardware-in-the-loop, co-simulation, and field deployments, potentially reducing apprehension for adoption of the technology. Also, some components, such as microgrid controllers for multiple microgrids, are still in the early stages of R&D, and need more time dedicated to them to flesh out the full capabilities.

To build a grid environment which is more interoperable, controllable, and reliable requires partnering with many utilities and vendors across the country and having them work together towards this vision. Otherwise, we end up with individual components which are solid, but were never designed to work together, resulting in a more costly, inefficient grid.



## 8. REFERENCES

- Albinali, H. F., A. P. Meliopoulos, and C. Vournas. 2017. "Dynamic state estimation-based centralized protection scheme." *2017 IEEE Manchester PowerTech*. 1–6. doi:10.1109/PTC.2017.7981259.
- Choi, Sungyun, and A. P. Sakis Meliopoulos. 2017. "Effective Real-Time Operation and Protection Scheme of Microgrids Using Distributed Dynamic State Estimation." *IEEE Transactions on Power Delivery* 32: 504–514. doi:10.1109/TPWRD.2016.2580638.
- Dewadasa, J. Manjula, Arindam Ghosh, and Gerard Ledwich. 2008. "Distance protection solution for a converter controlled microgrid." *Proceedings of the 15th National Power Systems Conference*.
- Dewadasa, M., A. Ghosh, and G. Ledwich. 2008. "Line protection in inverter supplied networks." *2008 Australasian Universities Power Engineering Conference*. 1–6.
- Lin, Yashen, Joseph Eto, Brian Johnson, Jack Flicker, Robert Lasseter, Hugo Villegas-Pico, Gab-Su Seo, Brian Pierre, and Abraham Ellis. 2020. *Research Roadmap on Grid-Forming Inverters*. National Renewable Energy Laboratory.
- Liu, Yu, A. P. Sakis Meliopoulos, Rui Fan, and Liangyi Sun. 2015. "Dynamic State Estimation based protection of microgrid circuits." *2015 IEEE Power Energy Society General Meeting*. 1–5. doi:10.1109/PESGM.2015.7286513.
- McDermott, Thomas, Bharat Vyakaranam, Rui Fan, Priya Thekkumparambath Mana, Travis Smith, Zhi Li, Joshua Hambrick, and Arthur Barnes. 2018. "Protective Relaying for Distribution and Microgrids Evolving from Radial to Bi-Directional Power Flow." *Proceedings 2018 Western Protective Relay Conference*. Spokane, WA.
- Meliopoulos, A. P. S., G. J. Cokkinides, P. Myrda, Y. Liu, R. Fan, L. Sun, R. Huang, and Z. Tan. 2017. "Dynamic State Estimation-Based Protection: Status and Promise." *IEEE Transactions on Power Delivery* 32: 320–330. doi:10.1109/TPWRD.2016.2613411.
- Schneider, Keven, Harsha Nagarajan, Annabelle Pratt, Mathew Reno, Ben Ollis, Francis Tuffner, Sai Nandanoori, et al. 2020. *Preliminary Design Process for Networked Microgrids*. Pacific Northwest National Laboratory.
- Venkata, S. S. (Mani), Matthew J. Reno, Ward Bower, Scott Manson, James Reilly, and George W. Sey Jr. 2019. "Microgrid protection: Advancing the state of the art." techreport, Sandia National Laboratories.

- [1] R. Uluski et al., "Microgrid Controller Design, Implementation, and Deployment: A Journey from Conception to Implementation at the Philadelphia Navy Yard," in IEEE Power and Energy Magazine, vol. 15, no. 4, pp. 50-62, July-Aug. 2017.
- [2] D. Ton and J. Reilly, "Microgrid Controller Initiatives: An Overview of R&D by the U.S. Department of Energy," in IEEE Power and Energy Magazine, vol. 15, no. 4, pp. 24-31, July-Aug. 2017.
- [3] G. Joos, J. Reilly, W. Bower and R. Neal, "The Need for Standardization: The Benefits to the Core Functions of the Microgrid Control System," in IEEE Power and Energy Magazine, vol. 15, no. 4, pp. 32-40, July-Aug. 2017.

## 9. IAB MEMBERS

<b>Name</b>	<b>Organization</b>	<b>Email</b>
Wade Malcolm	Open Energy Solutions	wade@openenergysolutionsinc.com
Scott Manson	SEL	scott_manson@selinc.com
Jim Reilly	Reilly Associates	j_reilly@verizon.net
Aleksandar Vukojevic	ComEd	Aleksandar.Vukojevic@comed.com



## **APPENDIX A.**